

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:21 pm

PWS ID: UTAH18051 **Name:** WEBB WELL WATER USERS
Legal Contact: WEBB WELL WATER USERS **Rating:** Approved
 CHARLES MASSON **Rating Date:** 06/09/1988
Address: 15075 S PINE HOLLOW **Activity Status:** Active
 BLUFFDALE, UT 84065
Phone Number: 801-254-5227
City Served (Area):
County: SALT LAKE COUNTY
System Type: Community **Last Inv Update:** 04/19/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 11/29/2007 **Total Dsgn Cap:**
Population: 90 **Surveyor:** LEE RICHARD PETER: **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office Phone Numbers	Emergency	Email Address
AC	MASSON, CHARLES		801-254-5227		

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	49
			49 Total Svc Connections

Storage

Total Storage: 89,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST002	TANK #2	Elevated	86,000 GAL	Steel		P	NO
ST001	WATER TANK	Ground	89,000 GAL	Steel		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TPPOI	POINT OF USE ARSENIC REMOVAL		A	

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	SOUTH WELL #1	Active	WL	16	600 GPM	600 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	NORTH WELL #2	Active	WL	12	400 GPM	400 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.